

## SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 283

Dated: 12.01.2025

It is certified that an inspection team headed by **Shri Chandra Bhushan, Executive Engineer, P.H.E.D. Samastipur** (Name of Officers with designation) from **PUBLIC HEALTH & ENGINEERING DEPARTMENT, SAMASTIPUR** (Name of Department/ Office) inspected the **RAVI SHANKAR PUBLIC SCHOOL, KHARAHIA, MANGALGARH, HASANPUR, SAMASTIPUR BIHAR** (Name & Address of the school) on 03.01.2025. (Date of inspection) and on the basis of Water Test Report (attached) bearing number **283** dated **08.01.2025** of DWTL.

Certified that the **RAVI SHANKAR PUBLIC SCHOOL**. (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of: - **ONE (1) YEAR**

*Chandra Bhushan*  
12/1/25  
**Executive Engineer**  
**P.H.E.D.**

Signature with Seal: .....**Samastipur**.....

Name: *Shri Chandra Bhushan.*

Designation: *Executive engineer.*

Name & Address of Department/ Office:

**P.H.E.D. SAMASTIPUR**

To,

The Manager

Ravi Shankar Public School

Kharahiya, Mangalgarh,

Samastipur, Bihar

Government of Bihar

Public Health Engineering Department

DIVISION :- SAMASTIPUR

MONTH:-JANUARY 2025

DISTRICT :- SAMASTIPUR			PARAMETERS										REMARKS		
S.N.	BLOCK	PANCHAYAT	VILLAGE	LOCATION OF SOURCE										MONTH:-JANUARY 2025	
				pH	TURB	EC	TDS	TH	Ca	Cl	Mg	Alka.	Fe	T.COL	
1	HASANPUR	DUDHPURA	KHARAHIYA	RAVI SHANKAR PUBLIC SCHOOL HASANPUR	7.1	1	209	136	68	18	22	8	56	0.2	-ve
				Acceptable Limit as per BIS 10500/2012	6.5-8.5	1 NTU	-	500	200	75 mg/l	250mg/l	30	200	1.0mg/l	-
				Permissible Limit* in Absence of Alternate source as per BIS 10500/2012	NR	5 NTU	-	2000	600	200	1000	100	600	NR	-

AK  
08/02/25  
CHEMIST  
P.H DIVISION SAMASTIPUR

  
08/02/25  
EXECUTIVE ENGINEER  
P.H DIVISION SAMASTIPUR